

## DECLARATION OF CONFORMITY

### VZ-40

#### Product name and type:

Circular variable air volume unit, OPTIMA-R, R-I

#### Producer:

**Company name:** Systemair Production a. s.

**Address:** Hlavná 371, 90043 Kalinkovo

**Company Id. Number:** 00683868

**Address of production:** Kalinkovo

#### Product description and determination:

Systemair circular VAV terminal units are available in two versions: Single skin Optima R & Double skin Optima R-I Single skin circular VAV terminal units are commonly used for return air applications or for supply applications at low system pressures. Double skin circular VAV terminal units are commonly used for supply or for return air applications at medium to high system pressures. Terminal units are ideal for single zone control with supply and return in Master and Slave setup such as offices, hotel rooms or meeting rooms where the required cooling and heating load will vary on demand.

#### Technical specification:

TechSpec\_TPI 40\_OPTIMA-R\_RI\_EN\_201609

#### Used standards:

EN 1751, VDI 6022, VDI 3803, SWKI VA104-01, ÖNORM H 6021, DIN EN 13779, DIN 1946 Blatt 4, SWKI 99-3, ÖNORM H 6020, STN EN 12589, STN EN 13182

The producer announce in accordance with law of constructional products, that

### **product is in conformity**

with stated technical and law instructions. This declaration of conformity is published by the producer on his own responsibility.

Kalinkovo 18.9.2017




**Systemair Production a.s.**

Hlavná 371, 900 43 Kalinkovo

IČ DPH: SK2020363290

IČO: 00 683 868 -05-

Stamp



Michal LASAN  
Quality and environment  
manager