



Reg. No. 041/P-007

NOTIFIED BODY 1396  
Osloboditeľov 282, 059 35 Batizovce, Slovakia  
Tel.+421 52 285 1611, www.fires.sk



## Certificate of constancy of performance

**1396-CPR-0069**

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product

### Circular fire damper PKIR E60S

used in heating, ventilation and air conditioning systems at fire boundaries to maintain compartmentation and protect means of escape in case of fire, which is automatically closed to limit spread of fire, heat and smoke when the ambient temperature reaches 72 °C, whereupon its properties and use of the product is in compliance with Assessment and verification of constancy of performance No. C1396/12/0032/4202/SC, issued by FIRES s.r.o., Notified Body 1396 on 06. 02. 2013,

placed on the market under the name or trade mark of

**Systemair Production a. s., Hlavná 371, 900 43 Kalinkovo, SR**

and produced in the manufacturing plant

**Systemair Production a. s., Hlavná 371, 900 43 Kalinkovo, SR**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

**EN 15650: 2010**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

**constancy of performance of the construction product.**

This certificate was first issued on 06<sup>th</sup> February 2013 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Batizovce, 13. 05. 2019



*Ing. Mária Gašperová*  
Ing. Mária Gašperová  
Head of Product Certification Body

090451 FIRES 136/C-31/01/2017-E