



NOTIFIED BODY 1396
Osloboditeľov 282, 059 35 Batizovce, Slovakia
Tel.+421 52 285 1611, www.fires.sk



Certificate of constancy of performance

1396-CPR-0147

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Systemair Smoke Control Damper S-SA2L

used on conditions described in the Assessment and verification of constancy of performance No. C1396/15/0026/4004/SC issued by FIRES, s.r.o., Notified Body 1396 on 24. 11. 2015, amended by an actual report of continuous surveillance No. I1396/18/0193/04/4004/IC issued by FIRES, s.r.o., Notified Body 1396 on 09. 01. 2019

placed on the market under the name or trade mark of

Systemair Production a. s., Hlavná 371, 900 43 Kalinkovo, SR

and produced in the manufacturing plant

Systemair Production a. s., Hlavná 371, 900 43 Kalinkovo, SR

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 12101-8: 2011

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on 09. 01. 2019 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Batizovce, 13. 05. 2019



Ing. Mária Gašperová
Ing. Mária Gašperová
Head of Product Certification Body

090455

FIRES 136a/C-31/01/2017-E