

Attestation of Conformity According to ATEX-Directive 2014/34/EU

The manufacturer: Robert Geiger
Technische Bauteile GmbH
Weiler Weg 14-18
89335 Ichenhausen

attested the conformity for the following product with ATEX-Directive 2014/34/EU

Product: Flexible connection

Description: Flexible connection for separation of structure-born sound or as expansion compensation for use in ventilators, heating and air conditioning devices as well as in air channels.


Type: FV-EX-P20
Type: FV-EX-P30
Type: FV-EX-P40
Type: FV-EX-DN

The minimum and health requirements are met by compliance with EN 1127-1:2019, DIN EN ISO 80079-36:2016 und EN IEC 60079-0:2018.

The component must have the following characterization

 II 2G Ex h IIC T6...T1 Gb X
 II 2D Ex h IIIC T85°C...T450°C Db X
-20 °C < T_{amb} < +70 °C

Ichenhausen, 16.01.2020


Norbert Lange
Managing Director

Technische Bauteile GmbH