

## Other controls



### CBT, electronic timer

Electronic timer with alternating contact. Setting range 1/2-1-2-4 or 4-8-16-24 hours respectively. The setting range can be limited down to a maximum time of 1/2 hours. IP44.

Type	Voltage [V]	Max input [A]	HxWxD [mm]
CBT	230V~	16	155x87x43



### KUR, digital time switch

Digital weekly timer with 8 different program steps (36 memory places) equipped with a changeover contact. Max. breaking current: 10 A. IP55.


Type	Voltage [V]	Max input [A]	HxWxD [mm]
KUR	230V~	10	175x85x105



MDC



MDCDC



MDC, magnetic door contact with time relay  
Starts the air curtain or increases from low to high speed when the door is opened. When the door is closed, the fan continues to run for the preset time (2 s–10 min). This prevents the fan from starting/stopping continuously and is especially suitable for doors that are frequently opened. Three alternating volt-free contacts 10 A, 230 V~ activated when the contacts make. A MDCDC is included in MDC. IP44.

### MDCDC, magnetic door contact

Indicates door status. Extra MDCDC are used when several doors are connected to a MDC. IP44.

Type	Voltage [V]	Max input [A]	HxWxD [mm]
MDC	230V~	10	155x87x43



### AGB304, position limit switch

Starts the air curtain or activates a fan speed control when the door is opened. When the door closes, AGB304 stops the air curtain or changes fan speed through a fan speed control. Alternating contact 4 A, 230 V~. IP67.