

# SysAqua

20 / 25 / 30 / 35 / 40 / 45 / 50 / 65 / 75 / 90 / 105 / 125

Air Cooled Water Chillers and Heat Pumps



19.5 → 119.1kW



19.4 → 128.0kW





## **ENERGY LABELLING MANUEL**

MANUEL D'ETIQUETAGE ENERGETIQUE

ENERGIEEFFIZIENZKENNZEICHUNGHANDBUCH

MANUALE DI ETICHETTATURA ENERGETICA

MANUAL DE ETIQUETADO ENERGETICO

English

Français

Deutsch

Italiano

Español

Model(s):	SYSAQUAH 20
Air-to-water heat pump:	yes
Water-to-water heat pump:	no
Brine-to-water heat pump:	no
Low-temperature heat pump:	no
Equipped with a supplementary heater:	no
Heat pump combination heater:	no

Parameters shall be declared for medium-temperature application, except for low-temperature heat pumps. For low-temperature heat pumps, parameters shall be declared for low-temperature application.

Parameters shall be declared for average, colder and warmer climate conditions.

Rated heat output (*)	Prated	19 kW	Seasonal space heating energy efficiency	$\eta_s$	132 %
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature $T_j$			Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature $T_j$		
$T_j = -7$ °C	P <sub>dh</sub>	13.4 kW	$T_j = -7$ °C	COP <sub>d</sub>	2.60
$T_j = +2$ °C	P <sub>dh</sub>	15.7 kW	$T_j = +2$ °C	COP <sub>d</sub>	3.17
$T_j = +7$ °C	P <sub>dh</sub>	12.2 kW	$T_j = +7$ °C	COP <sub>d</sub>	4.66
$T_j = +12$ °C	P <sub>dh</sub>	15.6 kW	$T_j = +12$ °C	COP <sub>d</sub>	4.73
$T_j =$ bivalent temperature	P <sub>dh</sub>	14.3 kW	$T_j =$ bivalent temperature	COP <sub>d</sub>	2.97
$T_j = -15$ °C	P <sub>dh</sub>	11.3 kW	$T_j = -15$ °C	COP <sub>d</sub>	1.95
Bivalent temperature	T <sub>biv</sub>	-4.0 °C	operation limit temperature	TOL	-20 °C
Cycling interval capacity for heating	P <sub>cyh</sub>	kW	Cycling interval efficiency	COP <sub>cyh</sub>	
Degradation co-efficient (**)	C <sub>dh</sub>	0.9	Heating water operating limit temperature	WTOL	55 °C
<b>Power consumption in modes other than active mode</b>			<b>Supplementary heater</b>		
Off mode	P <sub>OFF</sub>	kW	Rated heat output	P <sub>sup</sub>	kW
Thermostat-off mode	P <sub>TO</sub>	0.208 kW	Type of energy input		
Standby mode	P <sub>SB</sub>	0.068 kW			
Crankcase heater mode	P <sub>CK</sub>	0.068 kW			
<b>Other items</b>					
Capacity control	Staged		Rated air flow rate, outdoors		9 000 m <sup>3</sup> /h
Sound power level, indoors/outdoors	L <sub>WA</sub>	75 dB	Annual energy consumption	Q <sub>HE</sub>	11 594 kWh

(\*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating P<sub>designh</sub>, and the rated heat output of a supplementary heater P<sub>sup</sub> is equal to the supplementary capacity for heating sup(T<sub>j</sub>).

(\*\*) If C<sub>dh</sub> is not determined by measurement then the default degradation coefficient is C<sub>dh</sub> = 0.9.

Contact details:

**Systemair AC SAS**  
Route de Verneuil  
27570 Tillières-sur-Avre  
FRANCE

Model(s):	SYSAQUAH 25
Air-to-water heat pump:	yes
Water-to-water heat pump:	no
Brine-to-water heat pump:	no
Low-temperature heat pump:	no
Equipped with a supplementary heater:	no
Heat pump combination heater:	no

Parameters shall be declared for medium-temperature application, except for low-temperature heat pumps. For low-temperature heat pumps, parameters shall be declared for low-temperature application.

Parameters shall be declared for average, colder and warmer climate conditions.

Rated heat output (*)	Prated	23 kW	Seasonal space heating energy efficiency	$\eta_s$	128 %
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature $T_j$			Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature $T_j$		
$T_j = -7$ °C	P <sub>dh</sub>	16.24 kW	$T_j = -7$ °C	COP <sub>d</sub>	2.58
$T_j = +2$ °C	P <sub>dh</sub>	19.09 kW	$T_j = +2$ °C	COP <sub>d</sub>	3.27
$T_j = +7$ °C	P <sub>dh</sub>	14.92 kW	$T_j = +7$ °C	COP <sub>d</sub>	4.85
$T_j = +12$ °C	P <sub>dh</sub>	17.07 kW	$T_j = +12$ °C	COP <sub>d</sub>	5.79
$T_j =$ bivalent temperature	P <sub>dh</sub>	17.40 kW	$T_j =$ bivalent temperature	COP <sub>d</sub>	2.93
$T_j = -15$ °C	P <sub>dh</sub>	13.17 kW	$T_j = -15$ °C	COP <sub>d</sub>	1.97
Bivalent temperature	T <sub>biv</sub>	-3.5 °C	operation limit temperature	TOL	-20 °C
Cycling interval capacity for heating	P <sub>cyh</sub>	kW	Cycling interval efficiency	COP <sub>cyh</sub>	
Degradation co-efficient (**)	C <sub>dh</sub>	0.9	Heating water operating limit temperature	WTOL	55 °C
<b>Power consumption in modes other than active mode</b>			<b>Supplementary heater</b>		
Off mode	P <sub>OFF</sub>	kW	Rated heat output	P <sub>sup</sub>	kW
Thermostat-off mode	P <sub>TO</sub>	0.292 kW	Type of energy input		
Standby mode	P <sub>SB</sub>	0.068 kW			
Crankcase heater mode	P <sub>CK</sub>	0.068 kW			
<b>Other items</b>					
Capacity control	Staged		Rated air flow rate, outdoors		13 000 m <sup>3</sup> /h
Sound power level, indoors/outdoors	L <sub>WA</sub>	75 dB	Annual energy consumption	Q <sub>HE</sub>	13 817 kWh

(\*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating P<sub>designh</sub>, and the rated heat output of a supplementary heater P<sub>sup</sub> is equal to the supplementary capacity for heating sup( $T_j$ ).

(\*\*) If C<sub>dh</sub> is not determined by measurement then the default degradation coefficient is C<sub>dh</sub> = 0.9.

Contact details:

**Systemair AC SAS**  
Route de Verneuil  
27570 Tillières-sur-Avre  
FRANCE

Model(s):	SYSAQUAH 30
Air-to-water heat pump:	yes
Water-to-water heat pump:	no
Brine-to-water heat pump:	no
Low-temperature heat pump:	no
Equipped with a supplementary heater:	no
Heat pump combination heater:	no

Parameters shall be declared for medium-temperature application, except for low-temperature heat pumps. For low-temperature heat pumps, parameters shall be declared for low-temperature application.

Parameters shall be declared for average, colder and warmer climate conditions.

Rated heat output (*)	Prated	27 kW	Seasonal space heating energy efficiency	$\eta_s$	128 %
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature $T_j$			Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature $T_j$		
$T_j = -7$ °C	P <sub>dh</sub>	17.80 kW	$T_j = -7$ °C	COP <sub>d</sub>	2.49
$T_j = +2$ °C	P <sub>dh</sub>	23.70 kW	$T_j = +2$ °C	COP <sub>d</sub>	3.22
$T_j = +7$ °C	P <sub>dh</sub>	17.01 kW	$T_j = +7$ °C	COP <sub>d</sub>	5.28
$T_j = +12$ °C	P <sub>dh</sub>	19.16 kW	$T_j = +12$ °C	COP <sub>d</sub>	6.08
$T_j =$ bivalent temperature	P <sub>dh</sub>	20.09 kW	$T_j =$ bivalent temperature	COP <sub>d</sub>	2.86
$T_j = -15$ °C	P <sub>dh</sub>	12.56 kW	$T_j = -15$ °C	COP <sub>d</sub>	1.84
Bivalent temperature	T <sub>biv</sub>	-3.5 °C	operation limit temperature	TOL	-20 °C
Cycling interval capacity for heating	P <sub>cyh</sub>	kW	Cycling interval efficiency	COP <sub>cyh</sub>	
Degradation co-efficient (**)	C <sub>dh</sub>	0.9	Heating water operating limit temperature	WTOL	55 °C
<b>Power consumption in modes other than active mode</b>			<b>Supplementary heater</b>		
Off mode	P <sub>OFF</sub>	kW	Rated heat output	P <sub>sup</sub>	kW
Thermostat-off mode	P <sub>TO</sub>	0.268 kW	Type of energy input		
Standby mode	P <sub>SB</sub>	0.110 kW			
Crankcase heater mode	P <sub>CK</sub>	0.110 kW			
<b>Other items</b>					
Capacity control	Staged		Rated air flow rate, outdoors		13 000 m <sup>3</sup> /h
Sound power level, indoors/outdoors	L <sub>WA</sub>	75 dB	Annual energy consumption	Q <sub>HE</sub>	16 988 kWh

(\*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(T<sub>j</sub>).

(\*\*) If C<sub>dh</sub> is not determined by measurement then the default degradation coefficient is C<sub>dh</sub> = 0.9.

Contact details:

**Systemair AC SAS**  
Route de Verneuil  
27570 Tillières-sur-Avre  
FRANCE

Model(s):	SYSAQUAH 35
Air-to-water heat pump:	yes
Water-to-water heat pump:	no
Brine-to-water heat pump:	no
Low-temperature heat pump:	no
Equipped with a supplementary heater:	no
Heat pump combination heater:	no

Parameters shall be declared for medium-temperature application, except for low-temperature heat pumps. For low-temperature heat pumps, parameters shall be declared for low-temperature application.

Parameters shall be declared for average, colder and warmer climate conditions.

Rated heat output (*)	Prated	35 kW	Seasonal space heating energy efficiency	$\eta_s$	132 %
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature $T_j$			Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature $T_j$		
$T_j = -7$ °C	P <sub>dh</sub>	22.43 kW	$T_j = -7$ °C	COP <sub>d</sub>	2.72
$T_j = +2$ °C	P <sub>dh</sub>	27.70 kW	$T_j = +2$ °C	COP <sub>d</sub>	3.27
$T_j = +7$ °C	P <sub>dh</sub>	23.04 kW	$T_j = +7$ °C	COP <sub>d</sub>	5.22
$T_j = +12$ °C	P <sub>dh</sub>	25.95 kW	$T_j = +12$ °C	COP <sub>d</sub>	6.02
$T_j =$ bivalent temperature	P <sub>dh</sub>	25.70 kW	$T_j =$ bivalent temperature	COP <sub>d</sub>	3.00
$T_j = -15$ °C	P <sub>dh</sub>	21.53 kW	$T_j = -15$ °C	COP <sub>d</sub>	2.24
Bivalent temperature	T <sub>biv</sub>	-3.5 °C	operation limit temperature	TOL	-20 °C
Cycling interval capacity for heating	P <sub>cyh</sub>	kW	Cycling interval efficiency	COP <sub>cyh</sub>	
Degradation co-efficient (**)	C <sub>dh</sub>	0.9	Heating water operating limit temperature	WTOL	55 °C
Power consumption in modes other than active mode			Supplementary heater		
Off mode	P <sub>OFF</sub>	kW	Rated heat output	P <sub>sup</sub>	kW
Thermostat-off mode	P <sub>TO</sub>	0.351 kW	Type of energy input		
Standby mode	P <sub>SB</sub>	0.110 kW			
Crankcase heater mode	P <sub>CK</sub>	0.110 kW			
Other items					
Capacity control	Staged		Rated air flow rate, outdoors		16 000 m <sup>3</sup> /h
Sound power level, indoors/outdoors	L <sub>WA</sub>	-76 dB	Annual energy consumption	Q <sub>HE</sub>	21 391 kWh

(\*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating P<sub>designh</sub>, and the rated heat output of a supplementary heater P<sub>sup</sub> is equal to the supplementary capacity for heating sup(T<sub>j</sub>).

(\*\*) If C<sub>dh</sub> is not determined by measurement then the default degradation coefficient is C<sub>dh</sub> = 0.9.

Contact details:

**Systemair AC SAS**  
Route de Verneuil  
27570 Tillières-sur-Avre  
FRANCE

Model(s):	SYSAQUAH 40
Air-to-water heat pump:	yes
Water-to-water heat pump:	no
Brine-to-water heat pump:	no
Low-temperature heat pump:	no
Equipped with a supplementary heater:	no
Heat pump combination heater:	no

Parameters shall be declared for medium-temperature application, except for low-temperature heat pumps. For low-temperature heat pumps, parameters shall be declared for low-temperature application.

Parameters shall be declared for average, colder and warmer climate conditions.

Rated heat output (*)	Prated	37 kW	Seasonal space heating energy efficiency	$\eta_s$	133 %
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature $T_j$			Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature $T_j$		
$T_j = -7$ °C	P <sub>dh</sub>	27.52 kW	$T_j = -7$ °C	COP <sub>d</sub>	2.79
$T_j = +2$ °C	P <sub>dh</sub>	30.92 kW	$T_j = +2$ °C	COP <sub>d</sub>	3.28
$T_j = +7$ °C	P <sub>dh</sub>	25.08 kW	$T_j = +7$ °C	COP <sub>d</sub>	5.16
$T_j = +12$ °C	P <sub>dh</sub>	28.38 kW	$T_j = +12$ °C	COP <sub>d</sub>	6.12
$T_j =$ bivalent temperature	P <sub>dh</sub>	28.84 kW	$T_j =$ bivalent temperature	COP <sub>d</sub>	3.03
$T_j = -15$ °C	P <sub>dh</sub>	24.49 kW	$T_j = -15$ °C	COP <sub>d</sub>	2.34
Bivalent temperature	T <sub>biv</sub>	-3.5 °C	operation limit temperature	TOL	-20 °C
Cycling interval capacity for heating	P <sub>cyh</sub>	kW	Cycling interval efficiency	COP <sub>cyh</sub>	
Degradation co-efficient (**)	C <sub>dh</sub>	0.9	Heating water operating limit temperature	WTOL	55 °C
<b>Power consumption in modes other than active mode</b>			<b>Supplementary heater</b>		
Off mode	P <sub>OFF</sub>	kW	Rated heat output	P <sub>sup</sub>	kW
Thermostat-off mode	P <sub>TO</sub>	0.394 kW	Type of energy input		
Standby mode	P <sub>SB</sub>	0.110 kW			
Crankcase heater mode	P <sub>CK</sub>	0.110 kW			
<b>Other items</b>					
Capacity control	Staged		Rated air flow rate, outdoors		16 000 m <sup>3</sup> /h
Sound power level, indoors/outdoors	L <sub>WA</sub>	76 dB	Annual energy consumption	Q <sub>HE</sub>	22 364 kWh

(\*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(T<sub>j</sub>).

(\*\*) If C<sub>dh</sub> is not determined by measurement then the default degradation coefficient is C<sub>dh</sub> = 0.9.

Contact details:

**Systemair AC SAS**  
Route de Verneuil  
27570 Tillières-sur-Avre  
FRANCE

Model(s):	SYSAQUAH 45
Air-to-water heat pump:	yes
Water-to-water heat pump:	no
Brine-to-water heat pump:	no
Low-temperature heat pump:	no
Equipped with a supplementary heater:	no
Heat pump combination heater:	no

Parameters shall be declared for medium-temperature application, except for low-temperature heat pumps. For low-temperature heat pumps, parameters shall be declared for low-temperature application.

Parameters shall be declared for average, colder and warmer climate conditions.

Rated heat output (*)	Prated	42 kW	Seasonal space heating energy efficiency	$\eta_s$	126 %
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature $T_j$			Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature $T_j$		
$T_j = -7$ °C	Pdh	30.30 kW	$T_j = -7$ °C	COPd	2.57
$T_j = +2$ °C	Pdh	35.62 kW	$T_j = +2$ °C	COPd	3.21
$T_j = +7$ °C	Pdh	28.96 kW	$T_j = +7$ °C	COPd	4.87
$T_j = +12$ °C	Pdh	32.76 kW	$T_j = +12$ °C	COPd	5.69
$T_j =$ bivalent temperature	Pdh	32.37 kW	$T_j =$ bivalent temperature	COPd	2.89
$T_j = -15$ °C	Pdh	25.58 kW	$T_j = -15$ °C	COPd	1.99
Bivalent temperature	$T_{biv}$	-3.5 °C	operation limit temperature	TOL	-20 °C
Cycling interval capacity for heating	Pcyc	kW	Cycling interval efficiency	COPcyc	
Degradation co-efficient (**)	Cdh	0.9	Heating water operating limit temperature	WTOL	55 °C
<b>Power consumption in modes other than active mode</b>			<b>Supplementary heater</b>		
Off mode	$P_{OFF}$	kW	Rated heat output	$P_{sup}$	kW
Thermostat-off mode	$P_{TO}$	0.400 kW	Type of energy input		
Standby mode	$P_{SB}$	0.144 kW			
Crankcase heater mode	$P_{CK}$	0.144 kW			
<b>Other items</b>					
Capacity control	Staged		Rated air flow rate, outdoors		22 500 m <sup>3</sup> /h
Sound power level, indoors/outdoors	$L_{WA}$	80 dB	Annual energy consumption	$Q_{HE}$	26 717 kWh

(\*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup( $T_j$ ).

(\*\*) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0.9.

Contact details:

**Systemair AC SAS**  
Route de Verneuil  
27570 Tillières-sur-Avre  
FRANCE

Model(s):	SYSAQUAH 55
Air-to-water heat pump:	yes
Water-to-water heat pump:	no
Brine-to-water heat pump:	no
Low-temperature heat pump:	no
Equipped with a supplementary heater:	no
Heat pump combination heater:	no

Parameters shall be declared for medium-temperature application, except for low-temperature heat pumps. For low-temperature heat pumps, parameters shall be declared for low-temperature application.

Parameters shall be declared for average, colder and warmer climate conditions.

Rated heat output (*)	Prated	50 kW	Seasonal space heating energy efficiency	$\eta_s$	128 %
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature $T_j$			Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature $T_j$		
$T_j = -7$ °C	P <sub>dh</sub>	35.14 kW	$T_j = -7$ °C	COP <sub>d</sub>	2.61
$T_j = +2$ °C	P <sub>dh</sub>	41.24 kW	$T_j = +2$ °C	COP <sub>d</sub>	3.26
$T_j = +7$ °C	P <sub>dh</sub>	29.06 kW	$T_j = +7$ °C	COP <sub>d</sub>	4.78
$T_j = +12$ °C	P <sub>dh</sub>	32.86 kW	$T_j = +12$ °C	COP <sub>d</sub>	5.57
$T_j =$ bivalent temperature	P <sub>dh</sub>	37.51 kW	$T_j =$ bivalent temperature	COP <sub>d</sub>	2.94
$T_j = -15$ °C	P <sub>dh</sub>	29.72 kW	$T_j = -15$ °C	COP <sub>d</sub>	2.04
Bivalent temperature	T <sub>biv</sub>	-3.5 °C	operation limit temperature	TOL	-20 °C
Cycling interval capacity for heating	P <sub>cyh</sub>	kW	Cycling interval efficiency	COP <sub>cyh</sub>	
Degradation co-efficient (**)	C <sub>dh</sub>	0.9	Heating water operating limit temperature	WTOL	55 °C
<b>Power consumption in modes other than active mode</b>			<b>Supplementary heater</b>		
Off mode	P <sub>OFF</sub>	kW	Rated heat output	P <sub>sup</sub>	kW
Thermostat-off mode	P <sub>TO</sub>	0.508 kW	Type of energy input		
Standby mode	P <sub>SB</sub>	0.144 kW			
Crankcase heater mode	P <sub>CK</sub>	0.144 kW			
<b>Other items</b>					
Capacity control	Staged		Rated air flow rate, outdoors		22 500 m <sup>3</sup> /h
Sound power level, indoors/outdoors	L <sub>WA</sub>	80 dB	Annual energy consumption	Q <sub>HE</sub>	31 399 kWh

(\*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(T<sub>j</sub>).

(\*\*) If C<sub>dh</sub> is not determined by measurement then the default degradation coefficient is C<sub>dh</sub> = 0.9.

Contact details:

**Systemair AC SAS**  
Route de Verneuil  
27570 Tillières-sur-Avre  
FRANCE

Model(s):	SYSAQUAH 65
Air-to-water heat pump:	yes
Water-to-water heat pump:	no
Brine-to-water heat pump:	no
Low-temperature heat pump:	no
Equipped with a supplementary heater:	no
Heat pump combination heater:	no

Parameters shall be declared for medium-temperature application, except for low-temperature heat pumps. For low-temperature heat pumps, parameters shall be declared for low-temperature application.

Parameters shall be declared for average, colder and warmer climate conditions.

Rated heat output (*)	Prated	57 kW	Seasonal space heating energy efficiency	$\eta_s$	134 %
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature $T_j$			Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature $T_j$		
$T_j = -7$ °C	Pdh	44.48 kW	$T_j = -7$ °C	COPd	2.71
$T_j = +2$ °C	Pdh	52.32 kW	$T_j = +2$ °C	COPd	3.36
$T_j = +7$ °C	Pdh	34.02 kW	$T_j = +7$ °C	COPd	5.05
$T_j = +12$ °C	Pdh	38.22 kW	$T_j = +12$ °C	COPd	5.82
$T_j =$ bivalent temperature	Pdh	47.53 kW	$T_j =$ bivalent temperature	COPd	3.04
$T_j = -15$ °C	Pdh	41.86 kW	$T_j = -15$ °C	COPd	2.13
Bivalent temperature	$T_{biv}$	-3.5 °C	operation limit temperature	TOL	-20 °C
Cycling interval capacity for heating	Pcyc	kW	Cycling interval efficiency	COPcyc	
Degradation co-efficient (**)	Cdh	0.9	Heating water operating limit temperature	WTOL	55 °C
<b>Power consumption in modes other than active mode</b>			<b>Supplementary heater</b>		
Off mode	$P_{OFF}$	kW	Rated heat output	$P_{sup}$	kW
Thermostat-off mode	$P_{TO}$	0.467 kW	Type of energy input		
Standby mode	$P_{SB}$	0.144 kW			
Crankcase heater mode	$P_{CK}$	0.144 kW			
<b>Other items</b>					
Capacity control	Staged		Rated air flow rate, outdoors		30 000 m <sup>3</sup> /h
Sound power level, indoors/outdoors	$L_{WA}$	80 dB	Annual energy consumption	$Q_{HE}$	36 045 kWh

(\*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup( $T_j$ ).

(\*\*) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0.9.

Contact details:

**Systemair AC SAS**  
Route de Verneuil  
27570 Tillières-sur-Avre  
FRANCE

Model(s):	SYSAQUAH 75
Air-to-water heat pump:	yes
Water-to-water heat pump:	no
Brine-to-water heat pump:	no
Low-temperature heat pump:	no
Equipped with a supplementary heater:	no
Heat pump combination heater:	no

Parameters shall be declared for medium-temperature application, except for low-temperature heat pumps. For low-temperature heat pumps, parameters shall be declared for low-temperature application.

Parameters shall be declared for average, colder and warmer climate conditions.

Rated heat output (*)	Prated	72 kW	Seasonal space heating energy efficiency	$\eta_s$	133 %
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature $T_j$			Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature $T_j$		
$T_j = -7$ °C	P <sub>dh</sub>	49.41 kW	$T_j = -7$ °C	COP <sub>d</sub>	2.74
$T_j = +2$ °C	P <sub>dh</sub>	58.04 kW	$T_j = +2$ °C	COP <sub>d</sub>	3.36
$T_j = +7$ °C	P <sub>dh</sub>	43.14 kW	$T_j = +7$ °C	COP <sub>d</sub>	5.07
$T_j = +12$ °C	P <sub>dh</sub>	48.94 kW	$T_j = +12$ °C	COP <sub>d</sub>	5.83
$T_j =$ bivalent temperature	P <sub>dh</sub>	52.76 kW	$T_j =$ bivalent temperature	COP <sub>d</sub>	3.05
$T_j = -15$ °C	P <sub>dh</sub>	41.74 kW	$T_j = -15$ °C	COP <sub>d</sub>	2.19
Bivalent temperature	T <sub>biv</sub>	-3.5 °C	operation limit temperature	TOL	-20 °C
Cycling interval capacity for heating	P <sub>cyh</sub>	kW	Cycling interval efficiency	COP <sub>cyh</sub>	
Degradation co-efficient (**)	C <sub>dh</sub>	0.9	Heating water operating limit temperature	WTOL	55 °C
<b>Power consumption in modes other than active mode</b>			<b>Supplementary heater</b>		
Off mode	P <sub>OFF</sub>	kW	Rated heat output	P <sub>sup</sub>	kW
Thermostat-off mode	P <sub>TO</sub>	0.581 kW	Type of energy input		
Standby mode	P <sub>SB</sub>	0.144 kW			
Crankcase heater mode	P <sub>CK</sub>	0.144 kW			
<b>Other items</b>					
Capacity control	Staged		Rated air flow rate, outdoors		30 000 m <sup>3</sup> /h
Sound power level, indoors/outdoors	L <sub>WA</sub>	80 dB	Annual energy consumption	Q <sub>HE</sub>	42 358 kWh

(\*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(T<sub>j</sub>).

(\*\*) If C<sub>dh</sub> is not determined by measurement then the default degradation coefficient is C<sub>dh</sub> = 0.9.

Contact details:

**Systemair AC SAS**  
Route de Verneuil  
27570 Tillières-sur-Avre  
FRANCE

Model(s):	SYSAQUAH 90
Air-to-water heat pump:	yes
Water-to-water heat pump:	no
Brine-to-water heat pump:	no
Low-temperature heat pump:	no
Equipped with a supplementary heater:	no
Heat pump combination heater:	no

Parameters shall be declared for medium-temperature application, except for low-temperature heat pumps. For low-temperature heat pumps, parameters shall be declared for low-temperature application.

Parameters shall be declared for average, colder and warmer climate conditions.

Rated heat output (*)	Prated	85 kW	Seasonal space heating energy efficiency	$\eta_s$	128 %
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature $T_j$			Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature $T_j$		
$T_j = -7$ °C	Pdh	61.96 kW	$T_j = -7$ °C	COPd	2.69
$T_j = +2$ °C	Pdh	71.54 kW	$T_j = +2$ °C	COPd	3.23
$T_j = +7$ °C	Pdh	50.54 kW	$T_j = +7$ °C	COPd	4.63
$T_j = +12$ °C	Pdh	57.34 kW	$T_j = +12$ °C	COPd	5.39
$T_j =$ bivalent temperature	Pdh	65.69 kW	$T_j =$ bivalent temperature	COPd	2.96
$T_j = -15$ °C	Pdh	53.45 kW	$T_j = -15$ °C	COPd	2.51
Bivalent temperature	$T_{biv}$	-3.5 °C	operation limit temperature	TOL	-20 °C
Cycling interval capacity for heating	Pcyc	kW	Cycling interval efficiency	COPcyc	
Degradation co-efficient (**)	Cdh	0.9	Heating water operating limit temperature	WTOL	55 °C
Power consumption in modes other than active mode			Supplementary heater		
Off mode	$P_{OFF}$	kW	Rated heat output	$P_{sup}$	kW
Thermostat-off mode	$P_{TO}$	0.498 kW	Type of energy input		
Standby mode	$P_{SB}$	0.160 kW			
Crankcase heater mode	$P_{CK}$	0.160 kW			
Other items					
Capacity control	Staged		Rated air flow rate, outdoors		42 000 m <sup>3</sup> /h
Sound power level, indoors/outdoors	$L_{WA}$	83 dB	Annual energy consumption	$Q_{HE}$	53 665 kWh

(\*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup( $T_j$ ).

(\*\*) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0.9.

Contact details:

**Systemair AC SAS**  
Route de Verneuil  
27570 Tillières-sur-Avre  
FRANCE

Model(s):	SYSAQUAH 105
Air-to-water heat pump:	yes
Water-to-water heat pump:	no
Brine-to-water heat pump:	no
Low-temperature heat pump:	no
Equipped with a supplementary heater:	no
Heat pump combination heater:	no

Parameters shall be declared for medium-temperature application, except for low-temperature heat pumps. For low-temperature heat pumps, parameters shall be declared for low-temperature application.

Parameters shall be declared for average, colder and warmer climate conditions.

Rated heat output (*)	Prated	98 kW	Seasonal space heating energy efficiency	$\eta_s$	129 %
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature $T_j$			Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature $T_j$		
$T_j = -7$ °C	P <sub>dh</sub>	71.59 kW	$T_j = -7$ °C	COP <sub>d</sub>	2.73
$T_j = +2$ °C	P <sub>dh</sub>	82.12 kW	$T_j = +2$ °C	COP <sub>d</sub>	3.27
$T_j = +7$ °C	P <sub>dh</sub>	50.64 kW	$T_j = +7$ °C	COP <sub>d</sub>	4.60
$T_j = +12$ °C	P <sub>dh</sub>	57.44 kW	$T_j = +12$ °C	COP <sub>d</sub>	5.35
$T_j =$ bivalent temperature	P <sub>dh</sub>	75.69 kW	$T_j =$ bivalent temperature	COP <sub>d</sub>	3.00
$T_j = -15$ °C	P <sub>dh</sub>	62.22 kW	$T_j = -15$ °C	COP <sub>d</sub>	2.56
Bivalent temperature	$T_{biv}$	-3.5 °C	operation limit temperature	TOL	-20 °C
Cycling interval capacity for heating	P <sub>cyh</sub>	kW	Cycling interval efficiency	COP <sub>cyh</sub>	
Degradation co-efficient (**)	C <sub>dh</sub>	0.9	Heating water operating limit temperature	WTOL	55 °C
<b>Power consumption in modes other than active mode</b>			<b>Supplementary heater</b>		
Off mode	P <sub>OFF</sub>	kW	Rated heat output	P <sub>sup</sub>	kW
Thermostat-off mode	P <sub>TO</sub>	0.617 kW	Type of energy input		
Standby mode	P <sub>SB</sub>	0.173 kW			
Crankcase heater mode	P <sub>CK</sub>	0.173 kW			
<b>Other items</b>					
Capacity control	Staged		Rated air flow rate, outdoors		42 000 m <sup>3</sup> /h
Sound power level, indoors/outdoors	L <sub>WA</sub>	83 dB	Annual energy consumption	Q <sub>HE</sub>	60 991 kWh

(\*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(T<sub>j</sub>).

(\*\*) If C<sub>dh</sub> is not determined by measurement then the default degradation coefficient is C<sub>dh</sub> = 0.9.

Contact details:

**Systemair AC SAS**  
Route de Verneuil  
27570 Tillières-sur-Avre  
FRANCE

Model(s):	SYSAQUAH 125
Air-to-water heat pump:	yes
Water-to-water heat pump:	no
Brine-to-water heat pump:	no
Low-temperature heat pump:	no
Equipped with a supplementary heater:	no
Heat pump combination heater:	no

Parameters shall be declared for medium-temperature application, except for low-temperature heat pumps. For low-temperature heat pumps, parameters shall be declared for low-temperature application.

Parameters shall be declared for average, colder and warmer climate conditions.

Rated heat output (*)	Prated	118 kW	Seasonal space heating energy efficiency	$\eta_s$	131 %
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature $T_j$			Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature $T_j$		
$T_j = -7$ °C	Pdh	84.09 kW	$T_j = -7$ °C	COPd	2.76
$T_j = +2$ °C	Pdh	96.78 kW	$T_j = +2$ °C	COPd	3.33
$T_j = +7$ °C	Pdh	50.82 kW	$T_j = +7$ °C	COPd	4.54
$T_j = +12$ °C	Pdh	57.62 kW	$T_j = +12$ °C	COPd	5.28
$T_j =$ bivalent temperature	Pdh	89.02 kW	$T_j =$ bivalent temperature	COPd	3.05
$T_j = -15$ °C	Pdh	72.81 kW	$T_j = -15$ °C	COPd	2.26
Bivalent temperature	$T_{biv}$	-3.5 °C	operation limit temperature	TOL	-20 °C
Cycling interval capacity for heating	Pcyc	kW	Cycling interval efficiency	COPcyc	
Degradation co-efficient (**)	Cdh	0.9	Heating water operating limit temperature	WTOL	55 °C
<b>Power consumption in modes other than active mode</b>			<b>Supplementary heater</b>		
Off mode	$P_{OFF}$	kW	Rated heat output	$P_{sup}$	kW
Thermostat-off mode	$P_{TO}$	0.789 kW	Type of energy input		
Standby mode	$P_{SB}$	0.173 kW			
Crankcase heater mode	$P_{CK}$	0.173 kW			
<b>Other items</b>					
Capacity control	Staged		Rated air flow rate, outdoors		42 000 m <sup>3</sup> /h
Sound power level, indoors/outdoors	$L_{WA}$		Annual energy consumption	$Q_{HE}$	72 485 kWh

(\*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup( $T_j$ ).

(\*\*) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0.9.

Contact details:

**Systemair AC SAS**  
Route de Verneuil  
27570 Tillières-sur-Avre  
FRANCE





As part of our ongoing product improvement programme, our products are subject to change without prior notice. Non contractual photos.

## **Systemair AC SAS**

Route de Verneuil  
27570 Tillières-sur-Avre  
FRANCE

☎ : +33 (0)2 32 60 61 00

📠 : +33 (0)2 32 32 55 13



**ELM AQA 01-S-3GB**  
Part number : **J38356GB**  
Supersedes : **ELM AQA 01-S-2GB**