

# Physikalisch-Technische Bundesanstalt

Braunschweig and Berlin

## (1) EC-TYPE-EXAMINATION CERTIFICATE

(2) Equipment and Protective Systems Intended for Use in Potentially Explosive Atmospheres - **Directive 94/9/EC**



(3) EC Type Examination Certificate Number

**PTB 99 ATEX 3103**

(4) Equipment: Junction and Terminal Boxes Type 8118/...-...

(5) Manufacturer: R. Stahl Schaltgeräte GmbH

(6) Address: Bergstraße 2, D-74653 Künzelsau

(7) This equipment and any acceptable variation thereto are specified in the schedule to this certificate.

(8) The Physikalisch-Technische Bundesanstalt, notified body No. 0102 in accordance with Article 9 of the Council Directive 94/9/EC of 23 March 1994, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres, given in Annex II to the Directive.

The examination and test results are recorded in the confidential report PTB Ex 99-30041.

(9) Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

**EN 50 014:1997**

**EN 50 019:1994**

**EN 50 020:1994**

(10) If "X" is placed after the certificate number, it indicates that the equipment is subject to special conditions for safe use specified in the schedule to this certificate.

(11) This EC-type-examination Certificate relates only to the design and construction of the specified equipment in accordance with Directive 94/9/EC. Further requirements of this Directive apply to the manufacture and supply of this equipment.

(12) The marking of the equipment shall include the following:

 **II 2 G EEx e II T6/T5 or EEx ia/ib IIA/IIB/IIC T6/T5**

Zertifizierungsstelle Explosionsschutz  
By order:

Braunschweig, 19 April 1999

*signed: U. Engel* L.S.

Dr.-Ing. U. Engel  
Regierungsdirektor

# Physikalisch-Technische Bundesanstalt

Braunschweig and Berlin

## (13) SCHEDULE

### (14) EC-Type Examination Certificate PTB 99 ATEX 3103

#### (15) Description of the equipment

Junction and terminal boxes of polyester resin with a surface resistance  $\geq 1 \text{ G}\Omega$ , Type series 8118/...-..., for fixed installation, with built-in - separately certified - line-up or hood-type terminals for non-intrinsically safe or - separately certified - intrinsically safe circuits.

#### Marking of explosion protection

##### Fitting with terminals

- |  |  |
|--|--|
| - only for non-intrinsically safe circuits | EEx e II T6 or T5 for $T_{\text{amb}} \leq + 55 \text{ }^\circ\text{C}$        |
| - only for intrinsically safe circuits     | EEx ia/ib IIC/IIB /IIA T6  |
| - only for intrinsically safe circuits     | EEx ia/ib IIC/IIB /IIA T5 for $T_{\text{amb}} \leq +55 \text{ }^\circ\text{C}$ |

#### Technical data

##### Rated voltage:

max. 1100 V  
(depending on the operating voltage range of the terminals used)

Rated current, number of conductors and conductor cross section are determined in the associated additional sheets.

##### Ambient temperature range, max.:

$-50 \text{ }^\circ\text{C} \leq T \leq +55 \text{ }^\circ\text{C}$

##### Contact, foreign particles and water protection

min. IP 54 to EN 60 529: 1991

#### Note

The degree of protection - at least IP 54 - is achieved only when the tested gaskets, cable glands and stopping plugs are used properly.

Instruction of the manufacturer "Clean only with wet cloth" is to be followed.

The suitability for low ambient temperatures is visible by special marking. Only such separately certified sealing gaskets and built-in and built-on components, which are suitable for these temperatures, are used. Additional instructions of the manufacturer are to be followed.

(16) Test report PTB Ex 99-30041 (consisting of 6 pages, description and 2 drawings)

(17) Special requirements not applicable

(18) Essential health and safety requirements covered by standards

Zertifizierungsstelle Explosionsschutz  
By order:

Braunschweig, 19 April 1999

*signed: U. Engel* L.S.  
Dr.-Ing. U. Engel  
Regierungsdirektor

**1st SUPPLEMENT**  
according to Directive 94/9/EC Annex III.6  
**to EC-TYPE-EXAMINATION CERTIFICATE PTB 99 ATEX 3103**  
**(Translation)**

Equipment: Branching boxes or terminal boxes, type 8118/...-...

Marking:  **II 2 G EEx e II T6/T5 or EEx ia/ib IIA/IIB/IIC T6/T5**

Manufacturer: R. STAHL Schaltgeräte GmbH

Address: Am Bahnhof 30  
74638 Waldenburg (Württ.)

Description of supplements and modifications

The branching boxes or terminal boxes of type 8118/...-... can be used to house fuses designed to type of protection Encapsulation "m", which are covered by a separate certificate.

The enclosure may in addition be made from an alternative polyester resin.

The marking is extended to read

 **II 2 G EEx em II T6/T5/T4 or EEx ia/ib IIA/IIB/IIC T6/T5**

Technical data

Rated voltage: ..... up to 1100 V for terminal box without fuse  
up to 550 V for terminal box with fuse

Rated current: ..... max. 50 A

Conductor cross section: ..... max. 6 mm

Ambient temperatures:..... max. -50 °C to +55 °C

Current rating, number of conductors and conductor size are defined in the relevant specification sheets.

The composition of the protection symbol will be based on the types of protection of components actually used.

The ratings represent maximum values, actual values will be subject to the electrical equipment used from case to case. Depending on the system conditions, the mode of operation, the utilization category, etc., the manufacturer will specify the definitive ratings which will be within the range of these limiting values and will comply with the relevant standards.

Braunschweig und Berlin

1st SUPPLEMENT TO EC-TYPE-EXAMINATION CERTIFICATE PTB 99 ATEX 3103

## Notes for installation and use

The maximum number of conductors that can be used for each enclosure size is subject to the cross section and the admissible current rating and is shown in the attached specification sheets.


The surface resistance of the material used for the enclosure is  $10^{13}$  ohms. Due regard shall, therefore, be given to the note "to be cleaned with moist cloth only".

Test report: PTB Ex Ex 01-11021

Zertifizierungsstelle Explosionsschutz

Braunschweig, March 22, 2001

By order:



Dr.-Ing. U. Klausmeyer  
Regierungsdirektor



## 2nd SUPPLEMENT

according to Directive 94/9/EC Annex III.6

to EC-TYPE-EXAMINATION CERTIFICATE PTB 99 ATEX 3103

(Translation)

Equipment: Branching / terminal boxes, type 8118/...-...

Marking:  **II 2 G EEx em II T6/T5/T4 and EEx ia/ib IIA/IIB/IIC, T6/T5**

Manufacturer: R. STAHL Schaltgeräte GmbH

Address: Am Bahnhof 30, 74638 Waldenburg (Württ.), Germany

### Description of supplements and modifications

The branching / terminal boxes, type 8118/...-..., with plastic enclosure, may also be employed in areas in which a potentially explosive atmosphere as a mixture of dust and air can occasionally form.

The maximum ambient temperature is increased to +75 °C.

The branching / terminal boxes have been re-inspected on the basis of Standards EN 60079-0, EN 60079-7, EN 60079-11, EN 60079-18, EN 61241-0 and EN 61241-1.

The marking will thus change to:

 **II 2 G Ex em II T6/T5/T4 and Ex ia/ib IIA/IIB/IIC T6/T5**

 **II 2 D Ex tD A21 IP66 T 80 ° / T 95 °C / T 130 °C**

### Technical data

Rated voltage: .....	up to	1100 V for terminal boxes without fuse
	up to	550 V for terminal boxes with fuse
Rated current: .....	max.	50 A
Conductor size: .....	max.	6 mm
Ambient temperature range: .....	max.	-50 °C to +75 °C

Protection against contact, foreign

bodies and water: ..... IP66 in accordance with EN 60529 as a minimum

Rated current, number of conductors and conductor size are specified in the corresponding companion sheets.

The composition of the protection symbol is based on the types of protection of the components actually used.

Sheet 1/2

Rated values are maximum values, the actual electrical values are determined by mounted electrical apparatus. Within these limiting values complying with the appropriate standards the manufacturer specifies the final limiting values dependent on power supply specifications, operating mode, utilization category, etc.

Notes for manufacturing and operation

For the maximum number of conductors for each enclosure size, which is subject to the cross section and the permissible continuous current, reference is made to the attached companion sheets.

Since the surface resistance of the material used for the enclosure is  $10^{13}$  ohm, due regard must be given to the warning "Only use moist cloth for cleaning!" provided by the manufacturer.

Applied standards

EN 60079-0:2004

EN 60079-7:2003

EN 60079-11:2007

EN 60079-18:2004

EN 61241-0:2006

EN 61241-1:2004

Test report: PTB Ex 07-17090

Zertifizierungsstelle Explosionsschutz

Braunschweig, March 26, 2007

By order:

Dr.-Ing. U. Gaupe  
Direktor und Professor





# Supplementary Sheet 1

## to EC-Type Examination Certificate PTB 99 ATEX 3103

### Fitting of the junction boxes Type 8118/111 or Type 8118/113 and terminal boxes Type 8118/112 or Type 8118/114

**Maximum permissible continuous current of the terminal or maximum number of conductors** <sup>1)</sup> depending on the conductor size and the number of loaded terminals, for the temperature class T6 at  $T_a \leq 40 \text{ °C}$  or T5 at  $T_a \leq 55 \text{ °C}$  <sup>4)</sup>:

junction boxes Type 8118/111 or Type 8118/114 <sup>4)</sup>

number of loaded terminals	permissible rated current in A at conductor size		
	1,5 mm <sup>2</sup>	2,5 mm <sup>2</sup>	4 mm <sup>2</sup>
5	13	18	24
4	15	19	25
≤ 3	16	20	25

terminal boxes Type 8118/112 or Type 8118/114 <sup>4)</sup>

current in A	number of conductors <sup>1)</sup> at conductor size			
	1,5 mm <sup>2</sup>	2,5 mm <sup>2</sup>	4 mm <sup>2</sup>	
3	16			2)
6				
10		12	12	3)
16	6			
20	-	6		
25	-	-	8	
	8	6	6	
<b>max. number of terminals</b> depending on the cross section or the max. permissible conductor size of the terminals installed				

Note

1) Every entered conductor and every internal connection wire counts as conductor. Bridges and earth conductors are not counted.

2) additional conductors optional

3) When applying these tabular values, simultaneity factors or load factors according to IEC 439 may be considered. Mixed equipment with circuits with different cross sections and currents is possible by proportional utilization of the different tabular values:

example:	cross section / mm <sup>2</sup>	current / A	number of conductors	utilization
(generally)	1,5	10	10 (of 16)	= 63 %
	2,5	16	4 (of 12)	= 33 %
			total	= 96 % < 100 %

4) When mounting fuses ≤ 2 A ..... temperature class „T6“  
 When mounting fuses > 2 A bis ≤ 5A ..... temperature class „T5“  
 When mounting fuses ≤ 6,3 A ..... temperature class „T4“

# Supplementary Sheet 2



## to EC-Type Examination Certificate PTB 99 ATEX 3103

### Fitting of the junction boxes Type 8118/121 or Type 8118/123 and terminal boxes Type 8118/122 or Type 8118/124

**Maximum permissible continuous current of the terminal or maximum number of conductors** <sup>1)</sup> depending on the conductor size and the number of loaded terminals, for the temperature class T6 at  $T_a \leq 40 \text{ °C}$  or T5 at  $T_a \leq 55 \text{ °C}$  <sup>4)</sup>.

junction boxes Type 8118/121 or Type 8118/123 <sup>4)</sup>

number of loaded terminals	permissible rated current in A at conductor size			
	1,5 mm <sup>2</sup>	2,5 mm <sup>2</sup>	4 mm <sup>2</sup>	6 mm <sup>2</sup>
7	13	17	24	32
6	14	18	25	33
5		20		35
≤ 4	16			

terminal boxes type 8118/122 or Type 8118/124 <sup>4)</sup>

current in A	number of conductors <sup>1)</sup> at conductor size				
	1,5 mm <sup>2</sup>	2,5 mm <sup>2</sup>	4 mm <sup>2</sup>	6 mm <sup>2</sup>	
3	26				2)
6					
10		26			
16	6	14	22	20	3)
20	-	6			
25	-	-	8		
35	-	-	-	4	
	13	13	11	10	
<b>max. number of terminals</b> depending on the cross section or the max. permissible conductor size of the terminals installed					

Note

1) Every entered conductor and every internal connection wire counts as conductor. Bridges and earth conductors are not counted.

2) additional conductors optional

3) When applying these tabular values, simultaneity factors or load factors according to IEC 439 may be considered. Mixed equipment with circuits with different cross sections and currents is possible by proportional utilization of the different tabular values:

example:	cross section / mm <sup>2</sup>	current / A	number of conductors	utilization
(generally)	1,5	10	10 (of 16)	= 63 %
	2,5	16	4 (of 12)	= 33 %
			total	= 96 % < 100 %

4) When mounting fuses ≤ 2 A ..... temperature class „T6“  
 When mounting fuses > 2 A bis ≤ 5A ..... temperature class „T5“  
 When mounting fuses ≤ 6,3 A ..... temperature class „T4“

# Supplementary Sheet 3



## to EC-Type Examination Certificate PTB 99 ATEX 3103

### Fitting of the junction boxes Type 8118/131 or Type 8118/133 and terminal boxes Type 8118/132 or Type 8118/134

**Maximum permissible continuous current of the terminal or maximum number of conductors** <sup>1)</sup> depending on the conductor size and the number of loaded terminals, for the temperature class T6 at  $T_a \leq 40 \text{ °C}$  or T5 at  $T_a \leq 55 \text{ °C}$  <sup>4)</sup>:

junction boxes Type 8118/131 or Type 8118/133 <sup>4)</sup>

number of loaded terminals	permissible rated current in A at conductor size				
	1,5 mm <sup>2</sup>	2,5 mm <sup>2</sup>	4 mm <sup>2</sup>	6 mm <sup>2</sup>	10 mm <sup>2</sup>
7	13	17	24	32	44
6	14	18	25	33	46
5				49	
≤ 4	16	20		35	50

terminal boxes Type 8118/132 or Type 8118/134 <sup>4)</sup>

current in A	number of conductors <sup>1)</sup> at conductor size					
	1,5 mm <sup>2</sup>	2,5 mm <sup>2</sup>	4 mm <sup>2</sup>	6 mm <sup>2</sup>	10 mm <sup>2</sup>	
3						2)
6	36					
10	26	36				
16	6	18	32	24	20	3)
20	-	6	22			
25	-	-	8			
35	-	-	-	6		
50	-	-	-	-	4	
	18	18	16	12	10	
	<b>max. number of terminals</b> depending on the cross section or the max. permissible conductor size of the terminals installed					

Note

1) Every entered conductor and every internal connection wire counts as conductor. Bridges and earth conductors are not counted.

2) additional conductors optional

3) When applying these tabular values, simultaneity factors or load factors according to IEC 439 may be considered. Mixed equipment with circuits with different cross sections and currents is possible by proportional utilization of the different tabular values:

example:	cross section / mm <sup>2</sup>	current / A	number of conductors	utilization
(generally)	1,5	10	10 (of 16)	= 63 %
	2,5	16	4 (of 12)	= 33 %
			total	= 96 % < 100 %

4) When mounting fuses ≤ 2 A ..... temperature class „T6“  
 When mounting fuses > 2 A bis ≤ 5A ..... temperature class „T5“  
 When mounting fuses ≤ 6,3 A ..... temperature class „T4“



**PTB 99 ATEX 3103**

**Wir** (we; nous)

R. STAHL SCHALTGERÄTE GMBH, Bergstraße 2, D-74653 Künzelsau

**erklären in alleiniger Verantwortung, daß das Produkt**

hereby declare in our sole responsibility, that the product

déclarons de notre seule responsabilité, que le produit

**Abzweigdose und Klemmenkasten  
 Typ 8118/...-...**

Junction Box and Terminal Box

Type 8118/...-...

Boîte de Dérivation et de Raccordement

Type 8118/...-...

**auf das sich diese Erklärung bezieht, mit der/den folgenden Norm(en) oder normativen Dokumenten übereinstimmt**

which is the subject of this declaration, is in conformity with the following standard(s) or normative documents

auquel cette déclaration se rapporte, est conforme aux norme (s) ou aux documents normatifs suivants

**Bestimmungen der Richtlinie**

terms of the directive

prescription de la directive

**Titel und/oder Nr. sowie Ausgabedatum der Norm**

title and/or No. and date of issue of the standard

titre et/ou No. ainsi que date d'émission des normes

**94/9 EG: Geräte und Schutzsysteme zur bestimmungsgemäßen Verwendung in explosionsgefährdeten Bereichen**

94/9 EC: Equipment and protective systems intended for use in potentially explosive atmospheres

94/9 CE: Appareils et systèmes de protection destinés à être utilisés en atmosphères explosibles

EN 50014:1997

EN 50019:1994

EN 50020:1994

EN 60529:1991

**89/336 EWG: Elektromagnetische Verträglichkeit**

89/336 EEC: Electromagnetic compatibility

89/336 CEE: Compatibilité électromagnétique

EN 60947-1:1997

Künzelsau, 07.12.1999

**Ort und Datum**  
 Place and date  
 lieu et date

**Geschäftsbereichsleiter**  
 Divisional Director  
 Directeur de Division

**Leiter Qualitätsmanagement**  
 Head of quality management dept.  
 Chef du dept.assurance de qualité

